

Gunsan k-water quality test results

[June, 2025]

○ Water sampling date: June 2. ~ June 9.

○ Test period: June 2. ~ June 30.

No.	Test items	water standards	Test results		No.	Test items	water standards	Test results	
			Water Plant	Gunsan water				Water Plant	Gunsan water
1	Bacteria	100CFU/mlLess	0	0	31	Xylene	0.5mg/lLess	ND	0.005
2	Total Coliforms	ND/100ml	ND	ND	32	1,1-Dichloroethylene	0.03mg/lLess	ND	ND
3	E.coli	ND/100ml	ND	ND	33	Tetrachlorocarbon	0.002mg/lLess	ND	ND
4	Pb	0.01mg/lLess	ND	ND	34	1,1,2-trichloroethane	0.003mg/lLess	ND	ND
5	F	1.5mg/lLess	ND	ND	35	chloralhydrate	0.03mg/lLess	0.0038	0.0074
6	As	0.01mg/lLess	ND	ND	36	Dibromoacetonitrile	0.1mg/lLess	ND	ND
7	Se	0.01mg/lLess	ND	ND	37	Dichloroacetonitrile	0.09mg/lLess	0.017	0.0023
8	Hg	0.001mg/lLess	ND	ND	38	Trichloroacetonitrile	0.004mg/lLess	ND	ND
9	CN	0.01mg/lLess	ND	ND	39	Haloaceticacid	0.1mg/lLess	0.017	0.021
10	Cr	0.05mg/lLess	ND	ND	40	Residual chlorine	0.1~4.0mg/l	0.83	0.57
11	NH ₃ -N	0.5mg/lLess	ND	ND	41	Hardness	300mg/lLess	40	39
12	NO ₃ -N	10mg/lLess	1.3	1.2	42	Consumption of potassium permanganate	10mg/lLess	1.2	2.5
13	B	1.0mg/lLess	0.01	0.01	43	Smell	only the raw smell of disinfection	None	None
14	Cd	0.005mg/lLess	ND	ND	44	Taste	only the raw taste of disinfection	None	None
15	Phenol	0.005mg/lLess	ND	ND	45	Cu	1mg/lLess	ND	0.004
16	Diazinon	0.02mg/lLess	ND	ND	46	Color	5 Less	ND	ND
17	Parathion	0.06mg/lLess	ND	ND	47	ABS	0.5mg/lLess	ND	ND
18	Fenitrothion	0.04mg/lLess	ND	ND	48	pH	5.8 ~ 8.5	7.3	7.0
19	Carbaryl	0.07mg/lLess	ND	ND	49	Zn	3mg/lLess	ND	0.003
20	Trihalomethanes	0.1mg/lLess	0.027	0.038	50	Cl ⁻	250mg/lLess	15.8	16.0
21	chloroform	0.08mg/lLess	0.020	0.028	51	Residue on evaporation	500mg/lLess	94	102
22	1,1,1-Trichloroethane	0.1mg/lLess	ND	ND	52	Fe	0.3mg/lLess	ND	ND
23	Tetrachloroethylene	0.01mg/lLess	ND	ND	53	Mn	0.05mg/lLess	ND	ND
24	Trichloroethylene	0.03mg/lLess	ND	ND	54	Turbidity	0.5NTULess	0.05	0.05
25	bromochloromethane	0.03mg/lLess	0.007	0.010	55	SO ₄ ²⁻	200mg/lLess	6	6
26	dibromochloromethane	0.1mg/lLess	ND	ND	56	Al	0.2mg/lLess	0.02	0.03
27	Dichloromethane	0.02mg/lLess	ND	ND	57	1,4-dioxane	0.05mg/lLess	ND	ND
28	Benzene	0.01mg/lLess	ND	ND	58	Formaldehyde	0.5mg/lLess	ND	ND
29	Toluene	0.7mg/lLess	ND	ND	59	Bromate	0.01mg/lLess	0.0005	0.0005
30	Ethylbenzene	0.3mg/lLess	ND	ND	Test results			Suitable	Suitable
Test results			Suitable	Suitable	Test results			Suitable	Suitable